



EDF

**Electricité
de France**

High Temperature Heat PUMP in France

EDF R&D

RESEARCH AND DEVELOPMENT

Jean-Benoît RITZ

R & D

EDF strategy in term of Energy Efficiency

- **Be a European leader in the energy market with respect to the environment within a framework of economic performance**

Some Guidelines



- › **Increasing Energy efficiency**
- › **Reducing Energy consumption**
- › **Limiting the impact on the natural environment (greenhouse effect, CO2 emission reduction)**
- › **Developing renewable energies**

- **Develop the heat pump market is in the scope of EDF strategy.**
- **In this framework, we aim at being a significant player in Europe for thermodynamic heating systems**

EDF R&D supports the development of heat pump market

- **Contribute to define technical rules and specifications**
- **Technical and economical studies to compare initial and running cost with others systems**
- **Development of scientific models to predict the behaviour of systems or components**
- **In partnership with manufacturers design and development of new products**
- **Tests of products and systems in laboratory**
- **Technical training of sale's forces**
- **Set up a structure to examine and deal with poor quality installations to solve customers problems**
- **Energy monitoring on reference installations**

French residential heat pump market



- **Remarkable increase in the number of heat pumps sold since 1990 in France**
- **In 2003, 23800 HP sold in France**
market share : 42% air/air HP, 38% ground HP and 20% air/water HP
(Difficulties for assessing air/air systems used for mainly heating)
- **HP are mainly sold in the new buildings market**

Focus on heating in France

■ Single-family Houses

- 14 M of single-family houses (28 M of dwellings)
- New building construction rate per year : 1-2% of new individual houses,
- 300 000 owners renovate their heating system per year in existing single-family houses
- Market potential : 180000 boilers can be retrofited by HP each year (8.4 M oil/gaz boilers)


■ Market potential of HP for existing buildings is much greater than for new buildings

■ Heat distribution systems

- 60% by hydronic system with radiators (most of case) and floor heating
- Oil (20%) and gas (40%) of heating energy, mainly hydronic system

Heat pump in retrofit market

1 - Opportunities and barriers



How to replace Oil & Gas Burner heating by a HP ?

2 – Specifications of the High temperature HP

- **Description of the retrofit market**
 - **Traditional hydronic heating system sized in the range temperature of 90°C – 70°C or 80°C – 60°C**
 - **Systems designed for higher heating capacities than heat demands**
 - **Less needs because of insulation made since the building**
- **Distribution Temperatures may be reduced below the original design values**
- **Need of the product : Heat Pump producing water at 65 °C until –12 °C of external temperature can be suitable for substituting old boiler in the range temperature of 80°C – 60°C**

but **no product in the market in 2000 : the best : 50 °C until – 7°C**

3 - Collaboration for the develop. of the product

- Development started four years ago :

EDF, EPFL (Switzerland) , Viessmann/Satag (heat pump/boiler manufacturer), Copeland (scroll technology)

Technologic break around the compressor


Collaboration with COPELAND

- Enhance Vapor Injection scroll technology
- One stage cycle with economiser and intermediate injection of vapor



- Prototypes of Heat Pump built & tested in 2001/2002

- Heat Pumps of pilot production ready for field tests since end of 2002



4 - Technical data of the product



Ducted air/water Heat Pump (not reversible)
3 levels of electrical backup (3 kW – 6 kW – 3+6 kW)

Outside air T° limit (HP) = - 15 °C

Heating and tap water production

A -7°C / W 65 P_{heat} : 9,4 kW COP : 1,9

A+ 7°C/ W 35 P_{heat} : 11,8 kW COP : 3,8

(testing at EDF R&D)

Advantage : Production of water temperature at 65°C (HP only) for - 12 °C, external air temperature

5 - Tests at EDF R&D

Tests in natural climate

Seasonal performance

Real outside weather (Paris, $T_{base} = -7^{\circ}\text{C}$)
• Simulation of a single house (150 m²)

$-5^{\circ}\text{C} < T_{ext} < 15^{\circ}\text{C}$

$35^{\circ}\text{C} < T_{water} < 65^{\circ}\text{C}$

COP (dec.2001. – april 2002) = 2,8

COP (dec.2002. – april 2003) = 2,7



6 - Field tests with Viessmann S.A.

Test of 4 High Temperature Heat Pumps



Flers, 125 m² – oct./ nov. 2002
 Heating and hot water
 Propane



Moret, 130 m² – Janv 2004
 Heating and hot water gaz

Eglény, 120 m² – May 2002
 Heating and hot water
 Fuel

Vendennesse, 110 m²– oct./
 nov. 2002
 Heating and hot water Fuel




Target : Single house (around 150 m²)
Original system of heating : oil or gas boiler with radiators,
Design Temperature Text= - 10 °C, **Losses of heat** < 15 kW,
Hydronic distribution, 70°C max. water temperature in the inlet of radiators,

6 – Field tests





Field test in Flers (North of Paris)

- Built in 1770
- Heating (65°C) and hot water production (55°C)
(Parallel storage for heating)
- Alternate production with priority to tap water
(Design temperature $T = -6^{\circ}\text{C}$)



Field Test Flers in 2004



Global COP : 2,95

**DHW COP
summer : 3.21**


Period of the year	~January	~February	~March	~April	~May	~June to Sept.	~October	~Nov. to Dec.
Electricity input (MWh)	1.678	1.084	1.719	0.635	0.527	0.688	0.236	1.988
Electric backup heating (MWh)	0.303	0.142	0.251	0.143	0.13	0.1	0.047	0.079
Electric backup DHW (MWh)	0	0	0	0	0	0.008	0	0.001
Thermal Energy (MWh)	4.93	3.484	5.421	2.313	1.961	2.559	0.916	6.33
Number of days between 2 measurements	35	28	40	28	42	129	14	49
COP value	2.49	2.84	2.75	2.97	2.98	3.21	3.24	3.06
Outdoor air (°C)	3.82	4.73	3.75	9.25	12.95	15.44	10.35	4.39
Min outdoor air (°C)	-7	-2.4	-3.89	0.9	4.34	5.34	4.93	-4.73

6 – Field tests

Data measurements in progress in Egleny (South of Paris) :

To assess the performance of the combined production of heating and DHW, during the heating period 2004-2005, we measure both the heating COP and the DHW COP

Sample of Data during february 2005



Thermal energy :
6150 kWh for heating
349 kWh for DHW (5%)

Characteristics of the Heat Pump (February)

	min °C	Max °C	Average °C
Heating Supply temperature		69,0	56,8
Heating Return Temperature		60,0	50,5
DHW Supply temperature		64,0	40,1 (20 to 60)
Outside Temperature	-7,0	18,0	3,4
Ambiant Temperature living room	16,4	22,1	19,20
Ambiant Temperature bedroom	13,3	21,0	19,3
Heating COP			2,12
DHW COP			2,63
Global COP			2,14

Seasonal results soon

6 – Field tests Conclusion

- Seasonal COPs are between 2,4 and 3 depending on the external weather.

Example : Installation in Flers

Seasonal Heating COP : 2,95

(Lower T_{out} : -6°C, $T_{ambient}$: 20°C with HotWater)

Divided by 2 the price of energy bill (Propan Boiler)

- Customers satisfaction in term of comfort and energy is quite good *when the HP is properly installed*
 - No problem concerning the compressor and all components of the HP
 - Installation problems due to skills of installers (plumbers)
 - for a new product (need of technical rules and specifications for retrofitting)
- The HT HP is a good product for heating and tap water production with high potential : relevant and reliable
 - HT HP is a good retrofit solution



EDF

*Electricité
de France*

Thank you for your attention

R & D